

National Load Despatch Centre
Import of Punjab Transfer Capability for January 2024

Issue Date: 26th December 2023

Issue Time: 15:00

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st December 2024 to 10th December 2024	00-08	10000	500	9500	5497	4003	500	Annual Overhauling of Talwandi sabo Unit - 1
	08-18	10000	500	9500	5497	4003	500	
	18-24	10000	500	9500	5497	4003	500	
11th December 2024 to 31st December 2024	00-08	9500	500	9000	5497	3503		
	08-18	9500	500	9000	5497	3503		
	18-24	9500	500	9000	5497	3503		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

National Load Despatch Centre
Import of Punjab Transfer Capability for January 2024

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	26-Dec-23	01-01-2024 to 10-01-2024	Annual Overhauling of Talwandi sabo Unit - 1