

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2019**

Issue Date: 21st May 2019

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 19 to 31st July 19	00-24	6800	600	6200	4580	1620	-200	a) Revision in TTC/ATC due to change in Load - Generation Balance (LGBR) in Punjab. b) Revision in STOA margin due to revised TTC/ATC and change in operationalized LTA/MTOA 4680 MW to 4580 MW.
<b>Limiting Constraints</b>		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2019**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	21st May'19	1st July 19 to 31st July 19	a) Change in Load - Generation Balance (LGBR) in Punjab. b) Change in operationalized LTA/MTOA from 4680 MW to 4580 MW.