

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2020**

Issue Date: 17th July 2020

Issue Time: 1600 hrs

Revision No. 3

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st July 2020 to 17th July 2020	00-24	7200	600	6600	4515	2085		
18th July 2020 to 21st July 2020	00-24	7600	600	7000	4515	2485	400	Revision in TTC/ATC due to the following:- a) Forced outage of units at TSPL
22nd July 2020 to 31st July 2020	00-24	7200	600	6600	4515	2085		
<b>Limiting Constraints</b>	1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar							

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2020**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	28th April 2020	Whole Month	Revision in STOA margin due to change in allocation.
2	22nd June 2020	Whole Month	Revision in TTC/ATC due to the following:- a) Implementation of SPS at 400/220 kV Rajpura ICTs b) Generation restriction at TSPL
3	17th July 2020	18th July 2020 to 21st July 2020	Revision in TTC/ATC due to the following:- a) Forced outage of units at TSPL