

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Issue Date: 02nd July 2021

Issue Time: 11:45 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2021	00-24	7900	600	7300	4360	2940		
2nd July 2021	00-24	7900	600	7300	4360	2940		
3rd July 2021	00-24	7900	600	7300	4360	2940		On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
4th July 2021 to 31st July 2021	00-24	7900	600	7300	4860	2440		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
2	4th May 2021	1st July to 31st July 2021	Revised TTC/ATC due to planned outage of Talwandi Saboo Unit # 3
3	29th June 2021	1st July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
4	30th June 2021	2nd July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab
5	2nd July 2021	3rd July 2021	On request of NRLDC, STOA margin revised by 500 MW due to under utilisation of LTA by Punjab