

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2022**

Issue Date: 31st May 2022

Issue Time: 1000 Hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2022 to 31st July 2022	00-08	8700	500	8200	4860	3340	500	Addition of 500MVA ICT at 400/220kV Rajpura
	08-18	8700	500	8200	4860	3340	500	
	18-24	8700	500	8200	4860	3340	500	
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Nakodar, Ludhiana. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for July 2022**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	28.04.2022	1st July 2022 to 31st July 2022	Bus split at 400kV Moga
2	20.05.2022	1st July 2022 to 31st July 2022	Augmentation of 315MVA ICT by 500MVA ICT at Ludhiana(PG)
3	31.05.2022	1st July 2022 to 31st July 2022	Addition of 500MVA ICT at 400/220kV Rajpura