

National Load Despatch Centre
Import of Punjab Transfer Capability for July 2024

Issue Date: 12th July 2024

Issue Time: 10:30

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st July 2024 to 12th July 2024	00-08	10000	500	9500	5497	4003		
	08-18	10000	500	9500	5497	4003		
	18-24	10000	500	9500	5497	4003		
13th July 2024 to 14th July 2024	00-08	10400	500	9900	5497	4403		Forced Shutdown of Talwandi Sabo Unit - 3
	08-18	10400	500	9900	5497	4403		
	18-24	10400	500	9900	5497	4403		
15th July 2024 to 31st July 2024	00-08	10000	500	9500	5497	4003		
	08-18	10000	500	9500	5497	4003		
	18-24	10000	500	9500	5497	4003		
Limiting Constraints	<ol style="list-style-type: none"> 1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit. 							

Import of Punjab Transfer Capability for July 2024

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	20.05.2024	01.07.2024 to 31.07.2024	Commissioning of 400/220kV Dhanansu ICT1
2	12.07.2024	13.07.2024 to 14.07.2024	Forced Shutdown of Talwandi Sabo Unit - 3