

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2017**

Issue Date: 28/2/2017

Issue Time: 1745 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 17 to 30th June 17	00-24	6400	500	5900	4102	1798		
<b>Limiting Constraints</b>		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two ICTs. 2. (N-1) contingency of 400/220 kV ICT at Dhuri and 220 kV underlying network at Ludhiana						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2017**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>