

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2017

Issue Date: 18/5/2017

Issue Time: 1500 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 17 to 30th June 17	00-24	7100	600	6500	4261	2239	700	Revised considering outage of Talwandi Saboo generating plant
Limiting Constraints		1. (N-1) contingency of 500MVA 400/220 kV ICT at Amritsar critically over load other two 315 MVA ICTs. 2. Constraint in 220 kV underlying network at Ludhiana, Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2017

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	18th May 2017	Whole Month	Revised considering outage of Talwandi Saboo generating plant