

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2020

Issue Date: 28th April 2020

Issue Time: 1800 hrs

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2020 to 30th June 2020	00-24	7000	600	6400	4515	1885		Revision in STOA margin due to change in allocation.
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Amritsar (PG), Rajpura and N-1 contingency of 315 MVA ICT at Muktsar will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2020

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	28th April 2020	Whole Month	Revision in STOA margin due to change in allocation.