

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2021**

Issue Date: 15th June 2021

Issue Time: 2000 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2021 to 30th June 2021	00-24	7900	600	7300	4860	2440	0	
16th June 2021 to 17 <sup>th</sup> June 2021	00-09	8400	600	7800	4860	2940	500	Due to forced outage of Talwandi Saboo Unit-1
	09-17	7900	600	7300	4860	2440	0	
	17-24	8400	600	7800	4860	2940	500	
18 <sup>th</sup> June 2021 to 30 <sup>th</sup> June 2021	00-24	7900	600	7300	4860	2440	0	
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for June 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	12th April 2021	Whole month	1. Revision in TTC/ATC for summer/monsoon 2021 (Paddy season) 2. Revision in STOA margin due to increase in LTA/MTOA by 345 MW
2	4th May 2021	1st June to 30th June	Revised TTC/ATC due to planned outage of Talwandi Saboo Unit # 3
3	15th June 2021	16th June 2021 to 17th June 2021	Due to forced outage of Talwandi Saboo Unit-1