

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2023

Issue Date: 27-Jun-23

Issue Time: 10:00

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2023 to 10th June 2023	00-08	9000	500	8500	5197	3303		
	08-18	9000	500	8500	5197	3303		
	18-24	9000	500	8500	5197	3303		
11th June 2023 to 21st June 2023	00-08	9300	500	8800	5197	3603		
	08-18	9300	500	8800	5197	3603		
	18-24	9300	500	8800	5197	3603		
22nd June 2023 to 27th June 2023	00-08	9500	500	9000	5197	3803		
	08-18	9500	500	9000	5197	3803		
	18-24	9500	500	9000	5197	3803		
28th June 2023 to 30th June 2023	00-08	10000	500	9500	5197	4303	500	Due to forced outage of Talwandi Sabo Unit - 2
	08-18	10000	500	9500	5197	4303	500	
	18-24	10000	500	9500	5197	4303	500	
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

National Load Despatch Centre
Import of Punjab Transfer Capability for June 2023

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	09-Jun-23	11th to 30th June 2023	Capacity augmentation at 400/220kV Ludhiana & Moga. Outage of 315MVA ICT 1 at Nakodar for replacement with 500MVA.
2	21-Jun-23	22nd to 30th June 2023	Replacement of 315MVA ICT 1 at Nakodar with 500MVA ICT
3	27-Jun-23	28th to 30th June 2023	Due to forced outage of Talwandi Sabo Unit - 2