## **National Load Despatch Centre**

## Import of Punjab Transfer Capability for March 2019

Issue Date: 28th November 2018 Issue Time: 1600 hrs Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st March 19 to 31st March 19	00-24	7000	600	6400	4680	1720		
Limiting Constraints		(N-1) contingency of 500 MVA ICT at Ludhiana (PG), Amritsar (PG) and N-1 contigency of 315 MVA ICT at Makhu will crirically load other ICTs. 220 kV underlying network at Ludhiana and Amritsar						

## National Load Despatch Centre Import of Punjab Transfer Capability for March 2019

Revision No	Date of Revision	Period of Revision	Reason for Revision			