

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2018

Issue Date: 13/03/2018

Issue Time: 1500 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 18 to 31st May 18	00-24	6700	600	6100	5396	704		
Limiting Constraints		1. (N-1) contingency of 500 MVA ICT at Ludhiana (PG), Amritsar (PG) and N-1 contingency of 315 MVA ICT at Makhu will critically load other ICTs. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for May 2018

Revision No	Date of Revision	Period of Revision	Reason for Revision