## **National Load Despatch Centre**

## Import of Punjab Transfer Capability for November 2015

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 15 to 30th Nov 15	00-24	5700	300	5400	3790	1610		

Limiting Constraints	(n-1) contingency of ICT at Dhuri and (n-1) contingnecy of 220kV Moga(PG)-Moga(PSTCL)

## National Load Despatch Centre Total Transfer Capability for OCtober 2015

Revision No	Date of Revision	Period of Revision	Reason for Revision	Corridor Affected