## National Load Despatch Centre Import of Punjab Transfer Capability for November 2025

Issue Date: -17th l	Issue Time: 15:00					Revision No. 1			
Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)		Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments	
1st Nov 2025 to 30th Nov 2025	00-24	10600	500	10100	5497	4603	300	400/220kV ICT Capacity augmentation at Nakodar and Patran	
Limiting Constraints		<ol> <li>N-1 contigency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar, Muktsar.</li> <li>Loading close to N-1 contingency limits of 400/220kV Malerkotla and Patiala ICTs</li> <li>220 kV underlying network at Jalandhar, Ludhiana and Amritsar</li> </ol>							

## Import of Punjab Transfer Capability

Issue Date: -	Date of Revision	Period of Revision	<b>Reason for Revision</b>		
	17th Feb 25	19th Feb Onwords	400/220kV ICT Capacity augmentation at Nakodar and Patran		