

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for October 2023**

Issue Date: 1st October 2023

Issue Time: 10:00

Revision No. 1

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2023	00-08	9500	500	9000	5197	3803		
	08-18	9500	500	9000	5197	3803		
	18-24	9500	500	9000	5197	3803		
2nd October 2023	00-08	10000	500	9500	5197	4303		Due shutdown of TSPL Unit 2
	08-18	10000	500	9500	5197	4303		
	18-24	10000	500	9500	5197	4303		
3rd October 2023 to 31st October 2023	00-08	9500	500	9000	5197	3803		
	08-18	9500	500	9000	5197	3803		
	18-24	9500	500	9000	5197	3803		
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for October 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	1st October	2nd October	Due shutdown of TSPL Unit 2