

National Load Despatch Centre
Import of Punjab Transfer Capability for October 2021

Issue Date: 13th October 2021

Issue Time: 2000 hrs

Revision No. 3

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 9th October 2021	00-24	7400	600	6800	4860	1940		
10th October 2021 to 12th October 2021	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
13th October 2021	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
14th October 2021 to 15th October 2021	00-08	8300	600	7700	4860	2840	300	Revised due to forced outage of TSPL Unit 1
	08-18	8100	600	7500	4860	2640	400	
	18-24	8300	600	7700	4860	2840	300	
16th October 2021 to 31st October 2021	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

**National Load Despatch Centre
Import of Punjab Transfer Capability for October 2021**

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	9th October 2021	10th October 2021 to 12th October 2021	Revised due to forced outage of TSPL Unit 3
2	11th October 2021	13th Oct 2021- 31st Oct 2021	Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas.
3	13th October 2021	14th Oct 2021 - 15th Oct 2021	Revised due to forced outage of TSPL Unit 1