

National Load Despatch Centre
Import of Punjab Transfer Capability for October 2021

Issue Date: 17th October 2021

Issue Time: 1700 hrs

Revision No. 5

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st October 2021 to 9th October 2021	00-24	7400	600	6800	4860	1940		
10th October 2021 to 12th October 2021	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
13th October 2021	00-08	8000	600	7400	4860	2540		
	08-18	7700	600	7100	4860	2240		
	18-24	8000	600	7400	4860	2540		
14th October 2021	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
15th October 2021	00-04	8800	600	8200	4860	3340		
	04-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
16th October 2021 to 18th October 2021	00-08	8300	600	7700	4860	2840		
	08-18	8100	600	7500	4860	2640		
	18-24	8300	600	7700	4860	2840		
19th October 2021 to 31st October 2021	00-08	8000	600	7400	4860	2540	-300	Revised due to synchronisation of TSPL Unit 2
	08-18	7700	600	7100	4860	2240	-400	
	18-24	8000	600	7400	4860	2540	-300	
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Nakodar, Ludhiana. 2. 220 kV underlying network at Ludhiana and Amritsar						

National Load Despatch Centre
Import of Punjab Transfer Capability for October 2021

Revision No	Date of Revision	Period of Revision	Reason for Revision
1	9th October 2021	10th October 2021 to 12th October 2021	Revised due to forced outage of TSPL Unit 3
2	11th October 2021	13th Oct 2021- 31st Oct 2021	Due to 400kV bus split work completion at Moga. Variation in loadings during day and night in Rajpura, Ludhiana and Nakodar areas.
3	13th October 2021	14th Oct 2021 - 15th Oct 2021	Revised due to forced outage of TSPL Unit 1
4	14th October 2021	15th Oct 2021 - 31st Oct 2021	Revised due to forced outage of TSPL Unit 1 & 2
5	17th October 2021	19th Oct 2021 - 31st Oct 2021	Revised due to synchronisation of TSPL Unit 2