

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for September 2023**

Issue Date: 21st June 2023

Issue Time: 15:00

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st September 2023 to 30th September 2023	00-08	9500	500	9000	5197	3803	200	Replacement of 315MVA ICT 1 at Nakodar with 500MVA ICT.
	08-18	9500	500	9000	5197	3803	200	
	18-24	9500	500	9000	5197	3803	200	
<b>Limiting Constraints</b>		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC. 5. ATC/TTC limits may be reviewed if Punjab SLDC is not able to manage loading of 400/220kV ICTs below N-1 contingency limit.						

**National Load Despatch Centre**  
**Import of Punjab Transfer Capability for September 2023**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>
1	09-Jun-23	1st September 2023 to 30th September 2023	Capacity augmentation at 400/220kV Ludhiana & Moga. Outage of 315MVA ICT 1 at Nakodar for replacement with 500MVA.
2	21-Jun-23	1st September 2023 to 30th September 2023	Replacement of 315MVA ICT 1 at Nakodar with 500MVA ICT