

National Load Despatch Centre
Import of Jharkhand Transfer Capability for November 2021

Issue Date: 26th October 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st November 2021 to 30th November 2021	00-24	1460	57	1403	1265.247	138		TOTAL GENERATION 482 MW, total load 1943 MW
Limiting Constraints		1.132 kV Maithon-Jamtara 2. 132 kV Adityapur-Rajkarswan 3.220 KV Ramchandrapur Joda						