

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for November 2021**

Issue Date: 27th Oct 2021

Issue Time: 2000 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2021 to 30th Nov 2021	00 - 17	148	5	143	4	139	-	
	17 - 21	152	5	147	4	143	-	
	21 - 24	148	5	143	4	139	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						