

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for August 2021**

Issue Date: 26th July 2021

Issue Time: 2100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Aug 2021 to 31st Aug 2021	00 - 18	170	5	165	13	152	-	
	18- 22	180	5	175	13	162	-	
	22 - 24	170	5	165	13	152	-	
<b>Limiting Constraints</b>		N-1 of 220/132 kV ,100 MVA Dimapur ICT and limiting elements observed are 220/132 kV ,30 MVA Mokokchung ICTs						