

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for February 2021**

Issue Date: 28th January 2021

Issue Time: 1600 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2021 to 28th Feb 2021	00 - 17	190	5	185	13	172	-	
1st Feb 2021 to 28th Feb 2021	17- 23	160	5	155	13	142	-	
1st Feb 2021 to 28th Feb 2021	23 - 24	166	5	161	13	148	-	
<b>Limiting Constraints</b>		N-1 of 220/132 kV ,100 MVA Dimapur ICT and limiting elements observed are 220/132 kV ,30 MVA Mokokchung ICTs						

*Note : These are indicative figures to encourage self regulation among states.*

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for Feb 2021**

<b>Revision No</b>	<b>Date of Revision</b>	<b>Period of Revision</b>	<b>Reason for Revision</b>