

National Load Despatch Centre
Import of Nagaland Transfer Capability for November 2021

Issue Date: 27th Oct 2021

Issue Time: 2000 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Nov 2021 to 30th Nov 2021	00 - 17	170	5	165	13	152	-	
	17 - 21	180	5	175	13	162	-	
	21 - 24	170	5	165	13	152	-	
Limiting Constraints		N-1 of 220/132 kV ,100 MVA Dimapur ICT and limiting elements observed are 220/132 kV ,30 MVA Mokokchung ICTs						