

NATIONAL LOAD DESPATCH CENTRE

URGENT MARKET INFORMATION

Date of Issue: 07-MAR-2012

ATC OF NER-ER Corridor FOR 8th & 9th March, 2012

Due to cancellation of planned shut down of 400 kV Balipara – Bongaigaon-I from **0800 Hrs to 1600 Hrs on 08 & 09.03.12**, ATC for NER-ER Corridor is revised as follows:

1. Import capability of NER (w.e.f 08.03.12 to 09.03.12)

Link	Time period	TTC	LTOA	RM	ATC = TTC-LTOA-RM
ER→NER	00:00-24:00	450	204	35	211

The limiting factor in Import Capability of NER-ER Corridor is due to following critical links –

- **(n-1) contingency of 400/220 kV 315MVA ICT at Misa.**
- **High loading of 400/220 kV 315 MVA ICT at Balipara.**

During this period, export capability of NER is revised as follows:

2. Export capability of NER (w.e.f 08.03.12 to 09.03.12)

Link	Time period	TTC	LTOA	RM	ATC = TTC-LTOA-RM
NER→ER	00:00-24:00	570	0	100	470

The limiting factor in Export Capability of NER-ER corridor is due to following critical links –

- **(n-1) contingency of 400/220 kV 315 MVA ICT at Misa.**
- **High loading of 220 kV Balipara-Samaguri S/C line.**