

POWER SYSTEM OPERATION CORPORATION LIMITED

NATIONAL LOAD DESPATCH CENTRE

URGENT MARKET INFORMATION

Date of Issue: 03-JUNE-2012

Time of Issue: 11:30 Hrs

The TTC/ATC of ER-NER corridor is revised due to the S/D of the following elements:

1. 220kV BTPS - Salakati Ckt. II on 01-JUNE-12 from 0800 Hrs to 1600 Hrs.
2. 400kV Malda-Purnea D/C- 07:00 hrs of 30/05/2012 to 16:00 hrs of 23/06/2012 on continuous basis due to modification & stringing work at Loc No. 71 & 72.
3. Teesta-V HPS U#3 (170MW) under outage on continuous basis due to maintenance work of its GT. Expected date of resume of Generation from this unit is 7/6/12.
4. Improved generation in Tala HE and Chukha HE.

1. For 30/05/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-07:00	590	200	35	355
	07:00-17:00	550	200	35	315
	17:00-23:00	500	200	35	265
	23:00-24:00	550	200	35	315
NER→ER	00:00-24:00	570	0	100	470

2. For 31/05/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-17:00	550	200	35	315
	17:00-23:00	500	200	35	265
	23:00-24:00	550	200	35	315
NER→ER	00:00-24:00	570	0	100	470

3. For 01/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-08:00	550	200	35	315
	08:00-17:00	450	200	35	215
	17:00-23:00	500	200	35	265
	23:00-24:00	550	200	35	315
NER→ER	00:00-24:00	570	0	100	470

4. From 02/06/2012 to 03/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-17:00	550	200	35	315
	17:00-23:00	500	200	35	265
	23:00-24:00	550	200	35	315
NER→ER	00:00-24:00	570	0	100	470

5. From 04/06/2012 to 22/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-17:00	600	200	35	365
	17:00-23:00	550	200	35	315
	23:00-24:00	600	200	35	365
NER→ER	00:00-24:00	570	0	100	470

6. For 23/06/2012

Link	Time period	TTC	LTA	RM	ATC = TTC- RM-LTOA
ER→NER	00:00-16:00	550	200	35	315
	16:00-24:00	590	200	35	355
NER→ER	00:00-24:00	570	0	100	470