

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	180	5	175	6	169	-	
	17 - 21	180	5	175	6	169	-	
	21 - 24	180	5	175	6	169	-	

Limiting Constraints:N-1 of 132 kV Naharlagun - Pare and limiting observed at 132 kV Pare - Itanagar S/C

National Load Despatch Centre
Import of Assam Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	1580	40	1540	271	1269	-	
	17 - 21	1500	40	1460	271	1189	-	
	21 - 24	1580	40	1540	271	1269	-	
Limiting Constraints	N-1 of 220/132 kV, 160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV, 160 MVA ICT at BTPS							

National Load Despatch Centre
Import of Manipur Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	290	5	285	0	285	-	
	17 - 21	285	5	280	0	280	-	
	21 - 24	290	5	285	0	285	-	
Limiting Constraints		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

National Load Despatch Centre
Import of Meghalaya Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	230	10	220	39	181	-	
	17 - 21	250	10	240	39	201	-	
	21 - 24	230	10	220	39	181	-	
Limiting Constraints		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

National Load Despatch Centre
Import of Mizoram Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	148	5	143	4	139	-	
	17 - 21	152	5	147	4	143	-	
	21 - 24	148	5	143	4	139	-	
Limiting Constraints		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

National Load Despatch Centre
Import of Nagaland Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	170	5	165	13	152	-	
	17 - 21	180	5	175	13	162	-	
	21 - 24	170	5	165	13	152	-	
Limiting Constraints		N-1 of 220/132 kV ,100 MVA Dimapur ICT and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICTs						

National Load Despatch Centre
Import of Tripura Transfer Capability for December 2021

Issue Date: 29th Nov 2021

Issue Time: 1100 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Dec 2021 to 31st Dec 2021	00 - 17	365	6	359	0	359	-	
	17 - 21	310	6	304	0	304	-	
	21 - 24	365	6	359	0	359	-	
Limiting Constraints		N-1 of 132 kV SM-Nagar (TR) -SM Nagar(ISTS) S/C and limiting element observed is 132 kV PK-Bari (TR)- PK Bari (ISTS) S/C						