

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	195	5	190	6	184	-	
	18 - 22	195	5	190	6	184	-	
	22 - 24	195	5	190	6	184	-	

Limiting Constraints:N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C

National Load Despatch Centre
Import of Assam Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	2000	40	1960	271	1689	-	
	18 - 22	1950	40	1910	271	1639	-	
	22 - 24	2000	40	1960	271	1689	-	
Limiting Constraints	N-1 of 200 kV Misa-Samaguri I or II and Limiting constraint observed at 200 kV Misa-Samaguri II or I							

National Load Despatch Centre
Import of Manipur Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	320	5	315	52	263	-	
	18 - 22	320	5	315	52	263	-	
	22 - 24	320	5	315	52	263	-	
Limiting Constraints		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

National Load Despatch Centre
Import of Meghalaya Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	340	10	330	79	251	-	
	18 - 22	260	10	250	79	171	-	
	22 - 24	340	10	330	79	251	-	
Limiting Constraints		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

National Load Despatch Centre
Import of Mizoram Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	160	5	155	22	133	-	
	18 - 22	155	5	150	22	128	-	
	22 - 24	160	5	155	22	133	-	
Limiting Constraints		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

National Load Despatch Centre
Import of Nagaland Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	235	5	230	27	203	-	
	18 - 22	270	5	265	27	238	-	
	22 - 24	235	5	230	27	203	-	
Limiting Constraints		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

National Load Despatch Centre
Import of Tripura Transfer Capability for August 2022

Issue Date: 30th July 2022

Issue Time: 1200 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st August 2022 to 31st August 2022	00 - 18	340	6	334	196	138	-	
	18 - 22	310	6	304	196	108	-	
	22 - 24	340	6	334	196	138	-	
Limiting Constraints		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						