

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for May 2024**

Issue Date: 12th Apr 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	215	5	210	225	0	-	
	18 - 22	220	5	215	225	0	-	
	22 - 24	215	5	210	225	0	-	

**Limiting Constraints:N-1 of 132 kV Pare - Nirjuli and limiting observed at 132 kV Ranganadi-Lekhi S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for May 2024**

Issue Date: 12th Apr 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	2100	40	2060	1900	160	-	
	18 - 22	2100	40	2060	1900	160	-	
	22 - 24	2100	40	2060	1900	160	-	
<b>Limiting Constraints</b>	N-1 of 400 kV Bongaigaon Azara and Limiting constraint observed at 220 kV Balipara-Sonabil I & II							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for May 2024**

Issue Date: 12th Apr 2024

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	310	5	305	204	101	-	
	18 - 22	310	5	305	204	101	-	
	22- 24	310	5	305	204	101	-	
<b>Limiting Constraints</b>		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for May 2024**

**Issue Date: 12th Apr 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	370	10	360	238	122	-	
	18 - 22	300	10	290	238	52	-	
	22 - 24	370	10	360	238	122	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam 1-1 - Mawlai & limiting constraint observed at 132 kV Umiam 1-1-Umiam-1						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for May 2024**

**Issue Date: 12th Apr 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	155	5	150	150	0	-	
	18 - 22	145	5	140	150	0	-	
	22- 24	155	5	150	150	0	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for May 2024**

**Issue Date: 12th Apr 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	260	5	255	145	110	-	
	18 - 22	295	5	290	145	145	-	
	22- 24	260	5	255	145	110	-	

**Limiting Constraints**

N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for May 2024**

**Issue Date: 12th Apr 2024**

**Issue Time: 18:00 hrs**

**Revision No. 0**

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	GNA	Margin Available for T-GNA	Changes in TTC w.r.t. Last Revision	Comments
1st May 2024 to 31st May 2024	00 - 18	335	6	329	311	18	-	
	18- 22	320	6	314	311	3	-	
	22 - 24	335	6	329	311	18	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						