

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	200	5	195	6	189	-	
	17 - 21	170	5	165	6	159	-	
	21 - 24	200	5	195	6	189	-	

**Limiting Constraints:N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	1590	40	1550	271	1279	-	
	17 - 21	1555	40	1515	271	1244	-	
	21 - 24	1590	40	1550	271	1279	-	
<b>Limiting Constraints</b>	N-1 of 220 kV Azara-Sarusajai I or II and Limiting constraint observed at 220 kV Salakati-BTPS circuit II (circuit I is under shutdown)							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	315	5	310	52	258	-	
	17 - 21	310	5	305	52	253	-	
	21 - 24	315	5	310	52	258	-	
<b>Limiting Constraints</b>		<b>N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II &amp; III</b>						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for January 2023**

**Issue Date: 31st December 2022**

**Issue Time: 20:30 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Jan 2023 to 31st Jan 2023</b>	00 - 17	325	10	315	79	236	-	
	17 - 21	245	10	235	79	156	-	
	21 - 24	325	10	315	79	236	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam3 – Umiam I I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam I II						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	160	5	155	22	133	-	
	17 - 21	145	5	140	22	118	-	
	21 - 24	160	5	155	22	133	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	305	5	300	27	273	-	
	17 - 21	295	5	290	27	263	-	
	21 - 24	305	5	300	27	273	-	
<b>Limiting Constraints</b>		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for January 2023**

Issue Date: 31st December 2022

Issue Time: 20:30 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Jan 2023 to 31st Jan 2023	00 - 17	340	6	334	196	138	-	
	17 - 21	315	6	309	196	113	-	
	21 - 24	340	6	334	196	138	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						