

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for May 2023**

Issue Date: 28th April 2023

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00 - 17	195	5	190	6	184	-	
	17 - 21	165	5	160	6	154	-	
	21 - 24	195	5	190	6	184	-	

**Limiting Constraints:N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for May 2023**

Issue Date: 28th April 2023

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00 - 17	1680	40	1640	271	1369	-	
	17 - 21	1650	40	1610	271	1339	-	
	21 - 24	1680	40	1640	271	1369	-	
<b>Limiting Constraints</b>	N-1 of 220 kV Azara-Sarusajai I or II and Limiting constraint observed at 220 kV Azara-Sarusajai II or I							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for May 2023**

Issue Date: 28th April 2023

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00 - 17	310	5	305	52	253	-	
	17 - 21	310	5	305	52	253	-	
	21 - 24	310	5	305	52	253	-	
<b>Limiting Constraints</b>		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for May 2023**

**Issue Date: 28th April 2023**

**Issue Time: 19:00 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st May 2023 to 31st May 2023</b>	00 - 17	330	10	320	79	241	-	
	17 - 21	245	10	235	79	156	-	
	21 - 24	330	10	320	79	241	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for May 2023**

**Issue Date: 28th April 2023**

**Issue Time: 19:00 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st May 2023 to 31st May 2023</b>	00 - 17	155	5	150	22	128	-	
	18 - 22	145	5	140	22	118	-	
	22 - 24	155	5	150	22	128	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for May 2023**

Issue Date: 28th April 2023

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00 - 17	290	5	285	27	258	-	
	17 - 21	295	5	290	27	263	-	
	21 - 24	290	5	285	27	258	-	
<b>Limiting Constraints</b>		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for May 2023**

Issue Date: 28th April 2023

Issue Time: 19:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00 - 17	335	6	329	196	133	-	
	17 - 21	310	6	304	196	108	-	
	21 - 24	335	6	329	196	133	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						