

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|---------------------------------|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 195 | 5 | 190 | 6 | 184 | - | |
| | 17 - 21 | 165 | 5 | 160 | 6 | 154 | - | |
| | 21 - 24 | 195 | 5 | 190 | 6 | 184 | - | |

Limiting Constraints:N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C

National Load Despatch Centre
Import of Assam Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--|---------------------------------|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 1665 | 40 | 1625 | 271 | 1354 | - | |
| | 17 - 21 | 1640 | 40 | 1600 | 271 | 1329 | - | |
| | 21 - 24 | 1665 | 40 | 1625 | 271 | 1354 | - | |
| Limiting Constraints | N-1 of 220 kV Azara-Sarusajai I or II and Limiting constraint observed at 220 kV Azara-Sarusajai II or I | | | | | | | |

National Load Despatch Centre
Import of Manipur Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 310 | 5 | 305 | 52 | 253 | - | |
| | 17 - 21 | 310 | 5 | 305 | 52 | 253 | - | |
| | 21 - 24 | 310 | 5 | 305 | 52 | 253 | - | |
| Limiting Constraints | | N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III | | | | | | |

National Load Despatch Centre
Import of Meghalaya Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|--|---------------------------------|---|---------------------------|--|---|---|--|-----------------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 330 | 10 | 320 | 79 | 241 | - | |
| | 17 - 21 | 245 | 10 | 235 | 79 | 156 | - | |
| | 21 - 24 | 330 | 10 | 320 | 79 | 241 | - | |
| Limiting Constraints | | N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II | | | | | | |

National Load Despatch Centre
Import of Mizoram Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|--|---------------------------------|---|---------------------------|--|---|---|--|-----------------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 155 | 5 | 150 | 22 | 128 | - | |
| | 18 - 22 | 145 | 5 | 140 | 22 | 118 | - | |
| | 22 - 24 | 155 | 5 | 150 | 22 | 128 | - | |
| Limiting Constraints | | N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C | | | | | | |

National Load Despatch Centre
Import of Nagaland Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|--|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 290 | 5 | 285 | 27 | 258 | - | |
| | 17 - 21 | 295 | 5 | 290 | 27 | 263 | - | |
| | 21 - 24 | 290 | 5 | 285 | 27 | 258 | - | |
| Limiting Constraints | | N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III | | | | | | |

National Load Despatch Centre
Import of Tripura Transfer Capability for October 2022

Issue Date: 30th September 2022

Issue Time: 17:00 hrs

Revision No. 0

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) | Reliability Margin | Available Transfer Capability (ATC) | Long Term Access (LTA)/ Medium Term Open Access (MTOA) # | Margin Available for Short Term Open Access (STOA) | Changes in TTC w.r.t. Last Revision | Comments |
|---------------------------------------|--------------------------|---|--------------------|-------------------------------------|--|--|-------------------------------------|----------|
| 1st October 2022 to 31st October 2022 | 00 - 17 | 335 | 6 | 329 | 196 | 133 | - | |
| | 17 - 21 | 310 | 6 | 304 | 196 | 108 | - | |
| | 21 - 24 | 335 | 6 | 329 | 196 | 133 | - | |
| Limiting Constraints | | N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C | | | | | | |