

National Load Despatch Centre
Import of Arunachal Pradesh Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	320	5	315	6	288	-	
	18 - 22	320	5	315	6	288	-	
	22 - 24	320	5	315	6	288	-	

Limiting Constraints:N-1 of 132 kV Pare - Nirjuli and limiting observed at 132 kV Itanagar - Lekhi S/C

National Load Despatch Centre
Import of Assam Transfer Capability for Sept 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	1750	40	1710	271	1628	-	
	18 - 22	1700	40	1660	271	1628	-	
	22 - 24	1750	40	1710	271	1628	-	
Limiting Constraints	N-1 of 220 kV Balipara-Sonabil I or II and Limiting constraint observed at 220 kV Balipara-Sonabil II or I							

National Load Despatch Centre
Import of Manipur Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	310	5	305	52	234	-	
	18 - 22	310	5	305	52	234	-	
	22 - 24	310	5	305	52	234	-	
Limiting Constraints		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

National Load Despatch Centre
Import of Meghalaya Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	330	10	320	79	317	-	
	18 - 22	250	10	240	79	317	-	
	22 - 24	330	10	320	79	317	-	
Limiting Constraints		N-1 of 132 kV Umiam 1-1 - Mawlai & limiting constraint observed at 132 kV Umiam 1-1-Umiam-1						

National Load Despatch Centre
Import of Mizoram Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	155	5	150	22	156	-	
	18 - 22	145	5	140	22	156	-	
	22 - 24	155	5	150	22	156	-	
Limiting Constraints		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

National Load Despatch Centre
Import of Nagaland Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	290	5	285	27	194	-	
	18 - 22	295	5	290	27	194	-	
	22 - 24	290	5	285	27	194	-	
Limiting Constraints		N-1 of 220/132 kV, 30 MVA Mokokchung ICT I and limiting elements observed are 220/132 kV, 30 MVA Mokokchung ICT II and III						

National Load Despatch Centre
Import of Tripura Transfer Capability for September 2023

Issue Date: 01st Sep 2023

Issue Time: 18:00 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Sep 2023 to 30th Sep 2023	00 - 18	335	6	329	196	353	-	
	18 - 22	310	6	304	196	353	-	
	22 - 24	335	6	329	196	353	-	
Limiting Constraints		N-1 of 132 kV SM Nagar(ISTS) - Budhjungnagar S/C and limiting element observed is 132 kV SM Nagar(ISTS) - SM Nagar(TSECL) S/C						