

**National Load Despatch Centre**  
**Import of Tripura Transfer Capability for February 2022**

**Issue Date: 30th Jan 2021**

**Issue Time: 1700 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Feb 2022 to 28th Feb2022</b>	00 - 17	365	6	359	196	163	-	
	17 - 21	320	6	314	196	118	-	
	21 - 24	365	6	359	196	163	-	
<b>Limiting Constraints</b>		N-1 of 132 kV SM-Nagar (TR) -SM Nagar(ISTS) S/C and limiting element observed is 132 kV PK-Bari (TR)- PK Bari (ISTS) S/C						

**National Load Despatch Centre**  
**Import of Arunachal Pradesh Transfer Capability for February 2022**

Issue Date: 30th Jan 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2022 to 28th Feb2022	00 - 17	195	5	190	6	184	-	
	17 - 21	195	5	190	6	184	-	
	21 - 24	195	5	190	6	184	-	

**Limiting Constraints:N-1 of 132 kV Pare - Itanagar and limiting observed at 132 kV Naharlagun - Pare S/C**

**National Load Despatch Centre**  
**Import of Assam Transfer Capability for February 2022**

Issue Date: 30th Jan 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2022 to 28th Feb2022	00 - 17	1595	40	1555	271	1284	-	
	17 - 21	1565	40	1525	271	1254	-	
	21 - 24	1595	40	1555	271	1284	-	
<b>Limiting Constraints</b>	N-1 of 220/132 kV,160 MVA ICT at BTPS and Limiting constraint observed at 220/132 kV, 160 MVA ICT at BTPS							

**National Load Despatch Centre**  
**Import of Manipur Transfer Capability for February 2022**

Issue Date: 30th Jan 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2022 to 28th Feb 2022	00 - 17	335	5	330	52	278	-	
	17 - 21	330	5	325	52	273	-	
	21 - 24	335	5	330	52	278	-	
<b>Limiting Constraints</b>		N-1 of 132kV Imphal MA- Imphal PG Ckt I and constraint observed in 132 kV Imphal (MA)-Imphal (PG) II & III						

**National Load Despatch Centre**  
**Import of Meghalaya Transfer Capability for February 2022**

**Issue Date: 30th Jan 2021**

**Issue Time: 1700 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Feb 2022 to 28th Feb2022</b>	00 - 17	320	10	310	79	231	-	
	17 - 21	260	10	250	79	171	-	
	21 - 24	320	10	310	79	231	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Umiam3 – Umiam1 I & limiting constraint observed at 132 kV Umiam-Umiam 3-Umiam 1 II						

**National Load Despatch Centre**  
**Import of Mizoram Transfer Capability for February 2022**

Issue Date: 30th Jan 2021

Issue Time: 1700 hrs

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) #	Margin Available for Short Term Open Access (STOA)	Changes in TTC w.r.t. Last Revision	Comments
1st Feb 2022 to 28th Feb2022	00 - 17	165	5	160	22	138	-	
	17 - 21	160	5	155	22	133	-	
	21 - 24	165	5	160	22	138	-	
<b>Limiting Constraints</b>		N-1 of 132 kV Melriat-Silchar I or II and limiting constraint observed at 132 kV Aizawl Luangmual S/C						

**National Load Despatch Centre**  
**Import of Nagaland Transfer Capability for February 2022**

**Issue Date: 30th Jan 2021**

**Issue Time: 1700 hrs**

**Revision No. 0**

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC)</b>	<b>Reliability Margin</b>	<b>Available Transfer Capability (ATC)</b>	<b>Long Term Access (LTA)/ Medium Term Open Access (MTOA) #</b>	<b>Margin Available for Short Term Open Access (STOA)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
<b>1st Feb 2022 to 28th Feb2022</b>	00 - 17	180	5	175	27	148	-	
	17 - 21	190	5	185	27	158	-	
	21 - 24	180	5	175	27	148	-	
<b>Limiting Constraints</b>		N-1 of 220 kV Misa-Dimapur line and limiting elements observed are 220/132 kV, 30 MVA Mokochung ICTs						