




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

1-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	1.09	12.23	30.14	38.82	10.05	7.68	13.32	53.87	32.81	15.15	92.32	26.77

Average Frequency		50.02	Frequency Variation Index :		0.136	Standard Deviation :		0.115
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.48	18:02:50	Max	50.397	18:00:00
Min	49.72	4:21:10	Min	49.807	0:15:00