




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

6-May-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.00	0.23	6.69	42.16	41.32	8.38	1.22	6.92	68.03	25.05	15.52	98.78	31.02

Average Frequency		50.00	Frequency Variation Index :		0.057	Standard Deviation :		0.075
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.32	18:02:40	Max	50.180	17:15:00
Min	49.76	14:25:40	Min	49.841	14:30:00