




POWER SYSTEM OPERATION CORPORATION LIMITED
 NATIONAL LOAD DESPATCH CENTRE NEW DELHI

DURGAPUR:Frequency

National Grid Frequency Profile for

09-Aug-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.63	3.67	17.62	42.26	30.43	4.88	0.52	21.92	60.41	17.67	12.36	98.85	23.55

Average Frequency		49.97	Frequency Variation Index :		0.095	Standard Deviation :		0.091
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.251	6:05:00	Max	50.143	6:15:00
Min	49.59	19:17:00	Min	49.723	19:30:00

