




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for 17/06/2014

DADRI:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	5.94	10.98	17.48	31.92	26.47	6.75	0.47	34.41	47.50	18.09	10.91	93.59	20.35

Average Frequency		49.93	Frequency Variation Index :		0.224	Standard Deviation :		0.133
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.236	18:03:30	Max	50.146	8:15:00
Min	49.40	22:07:00	Min	49.519	22:15:00

