




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MEERUT:Frequency

National Grid Frequency Profile for

18-Jul-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.23	1.04	9.27	35.71	41.79	10.86	1.11	10.54	59.78	29.68	18.28	98.66	29.80

Average Frequency	50.00	Frequency Variation Index :	0.071	Standard Deviation :	0.084
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.25	7:03:10	Max	50.212	7:15:00
Min	49.66	19:49:00	Min	49.761	20:00:00

