




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

BINAGURI:Frequency

National Grid Frequency Profile for

01/06/14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	1.60	5.00	12.27	25.49	33.33	14.48	7.83	18.88	41.01	40.12	17.91	90.57	17.30

Average Frequency		50.01	Frequency Variation Index :		0.183	Standard Deviation :		0.135
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.486	18:02:50	Max	50.406	18:15:00
Min	49.51	22:35:00	Min	49.658	22:45:00