




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for

03/06/14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	10.13	23.45	23.54	26.38	14.95	1.50	0.05	57.14	36.94	5.91	4.41	89.82	15.28

Average Frequency	49.86	Frequency Variation Index :	0.350	Standard Deviation :	0.129
--------------------------	--------------	------------------------------------	--------------	-----------------------------	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.207	6:01:40	Max	50.083	6:15:00
Min	49.47	22:04:50	Min	49.583	22:15:00