




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for

14-05-2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.19	2.73	15.36	32.66	34.44	10.57	4.05	18.68	53.52	27.79	13.60	95.76	25.37

Average Frequency		50.00	Frequency Variation Index :		0.113	Standard Deviation :		0.107
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.33	18:04:50	Max	50.247	4:00:00
Min	49.68	22:12:00	Min	49.764	22:00:00