




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

National Grid Frequency Profile for 23-05-14

MOHINDERGARH:Frequency



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.98	10.23	28.99	36.32	19.27	3.55	0.66	40.22	49.27	10.51	6.34	98.36	18.22

<b>Average Frequency</b>		<b>49.93</b>	<b>Frequency Variation Index :</b>		<b>0.160</b>	<b>Standard Deviation :</b>		<b>0.102</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.247	6:03:10	Max	50.147	6:15:00
Min	49.65	10:16:00	Min	49.767	14:00:00