




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

MOHINDERGARH:Frequency

National Grid Frequency Profile for

25-04-2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.38	0.84	9.44	34.90	39.35	11.78	3.30	10.67	60.60	28.73	13.67	96.31	31.02

Average Frequency		50.01	Frequency Variation Index :		0.088	Standard Deviation :		0.094
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.33	17:12:40	Max	50.244	17:15:00
Min	49.64	0:06:40	Min	49.785	0:15:00