




POWER SYSTEM OPERATION CORPORATION LIMITED
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

NTPC-VINDHYACHAL:Frequency

National Grid Frequency Profile for 26/05/2014



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.78	6.86	20.62	30.02	34.53	7.15	0.04	28.28	47.92	23.81	16.64	99.19	19.78

Average Frequency		49.96	Frequency Variation Index :		0.124	Standard Deviation :		0.105
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.2	13:02:30	Max	50.122	2:45:00
Min	49.54	22:08:00	Min	49.683	22:15:00