




**POWER SYSTEM OPERATION CORPORATION LIMITED**  
NATIONAL LOAD DESPATCH CENTRE NEW DELHI

HISSAR:Frequency

National Grid Frequency Profile for 28-05-14



<49.2	<49.7	49.7-49.8	49.8-49.9	49.9-50.0	50.0-50.1	50.1-50.2	>50.2	<49.90	49.90-50.05	>50.05	50.05-50.1	49.7-50.2	49.97-50.03
0	0.74	6.70	16.23	26.70	34.93	12.93	1.77	23.68	42.85	33.47	18.85	97.49	16.02

<b>Average Frequency</b>		<b>49.99</b>	<b>Frequency Variation Index :</b>		<b>0.135</b>	<b>Standard Deviation :</b>		<b>0.115</b>
--------------------------	--	--------------	------------------------------------	--	--------------	-----------------------------	--	--------------

Instantaneous Frequency			15 minute average Frequency		
MAX	50.322	18:02:50	Max	50.195	6:15:00
Min	49.64	14:12:50	Min	49.755	22:15:00