

National Load Despatch Centre
Import of Punjab Transfer Capability for
Jun-24

Issue Date: 29-05-2024

Issue Time: 15:00

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC)	Reliability Margin	Available Transfer Capability (ATC)	Approved GNA (MW)	Margin Available for T-GNA (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	10000	500	9500	5497	4003	500	Commissioning of 400/220kV Dhanansu ICT1 and forced outage of LehraMohabbat Unit 2
Limiting Constraints		1. N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Muktsar. 2. Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Dhanansu and Jalandhar ICTs 3. 220 kV underlying network at Jalandhar, Ludhiana and Amritsar 4. Punjab SLDC to ensure minimum internal generation above 5000MW for this ATC/TTC.						

**National Load Despatch Centre
Import Capability of Uttar Pradesh for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	16500	600	15900	9779	6121		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Azamgarh, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

**National Load Despatch Centre
Import Capability of Haryana for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	9336	250	9086	5418	3668		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICTs at Deepalpur and Panipat(BBMB)						

**National Load Despatch Centre
Import Capability of Rajasthan for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	7600	600	7000	5689	1311		https://sldc.rajasthan.gov.in/rrvpnl/scheduling/download
Limiting Constraints		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Bhinmal ICTs						

National Load Despatch Centre
Import Capability of Delhi for

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	7300	300	7000	4810	2190		https://www.delhisldc.org/resources/atctcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre
Import Capability of HP for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	1680	100	1580	1130	450		https://hpslhc.com/mrm_category/ttc-atc-report/
Limiting Constraints		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kuniyar transformers						

**National Load Despatch Centre
Import Capability of Uttarakhand for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	1700	100	1600	1402	198		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre
Import Capability of J&K for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	2800	100	2700	1977	723		
Limiting Constraints		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						

**National Load Despatch Centre
Import Capability of Chandigarh for**

Jun-24

01-06-2024

Issue Date: 29-05-2024

Issue Time: 1600

Revision No. 2

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st June 2024 to 31st June 2024	00-24	400	20	380	342	38		
Limiting Constraints		N-1 contingency of 220kV Nallagarh-Kishengarh						