

**National Load Despatch Centre**  
**Import Capability of Punjab for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2025 to 31th March 2025	00-24	9500	500	9000	5497	3503		<a href="https://www.punjab.sldc.org/ATC_TTC.aspx">https://www.punjab.sldc.org/ATC_TTC.aspx</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICTs at Rajpura, Ludhiana, Jalandhar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla, Moga and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar						

**National Load Despatch Centre**  
**Import Capability of UP for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2025 to 31th March 2025	00-24	16100	600	15500	9779	5721		<a href="https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde">https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Azamgarh, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

**National Load Despatch Centre**  
**Import Capability of Haryana for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2025 to 31th March 2025	00-24	9100	250	8850	5418	3432		<a href="https://hvpn.org.in/#/atcttc">https://hvpn.org.in/#/atcttc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV ICTs at Deepalpur and Panipat(BBMB)						

**National Load Despatch Centre**  
**Import Capability of Rajasthan for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2025 to 31th March 2025	00-24	7600	600	7000	5689	1311		<a href="https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads">https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Bhinmal ICTs						

**National Load Despatch Centre**  
**Import Capability of Delhi for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2025 to 31th March 2025	00-24	7300	300	7000	4810	2190		<a href="https://www.delhisldc.org/resources/atcttcreport.pdf">https://www.delhisldc.org/resources/atcttcreport.pdf</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

**National Load Despatch Centre  
Import Capability of HP for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2025 to 31th March 2025	00-24	1680	100	1580	1130	450		<a href="https://hpsldc.com/mrm_category/ttc-atc-report/">https://hpsldc.com/mrm_category/ttc-atc-report/</a>
<b>Limiting Constraints</b>		High loading of 220kV Hamirpur-Hamirpur D/C. Overloading of 2*200MVA Kunihar transformers						

**National Load Despatch Centre**  
**Import Capability of Uttarakhand for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2025 to 31th March 2025	00-24	1700	100	1600	1402	198		<a href="https://uksldc.in/ttc-atc">https://uksldc.in/ttc-atc</a>
<b>Limiting Constraints</b>		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

**National Load Despatch Centre**  
**Import Capability of J&K for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Approved General Network Access (MW)	Margin Available for Temporary General Network Access(MW)	Changes in TTC w.r.t. Last Revision	Comments
1st March 2025 to 31th March 2025	00-24	2900	100	2800	1977	823		
<b>Limiting Constraints</b>		N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora						



**National Load Despatch Centre**  
**Import Capability of Chandigarh for March 2025**

Issue Date: - 30 March, 24

Issue Time: 1600

Revision No. 0

<b>Date</b>	<b>Time Period in IST (hrs)</b>	<b>Total Transfer Capability (TTC) (MW)</b>	<b>Reliability Margin (MW)</b>	<b>Available Transfer Capability (ATC) (MW)</b>	<b>Approved General Network Access (MW)</b>	<b>Margin Available for Temporary General Network Access(MW)</b>	<b>Changes in TTC w.r.t. Last Revision</b>	<b>Comments</b>
1st March 2025 to 31th March 2025	00-24	400	20	380	342	38		
<b>Limiting Constraints</b>		N-1 contingency of 220kV Nallagarh-Kishengarh						