

National Load Despatch Centre
Import Capability of Uttar Pradesh for May 2023

Issue Date: -30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	15100	600	14500	7060	7440		https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde
Limiting Constraints		N-1 contingency of 400/220kV Azamgarh, Obra, Allahabad(PG), Gorakhpur (UP), Sarnath, Lucknow (PG) ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Haryana for May 2023

Issue Date: - 30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	9100	600	8500	3035	5465		https://hvpn.org.in/#/atcttc
Limiting Constraints		N-1 contingency of 400/220kV ICTs at Deepalpur, Panipat(BBMB) and Kurukshetra(PG)						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Rajasthan for May 2023

Issue Date: -30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	7600	600	7000	3335	3665		https://sldc.rajabhan.gov.in/rrvpn/scheduling/downloads
Limiting Constraints		N-1 contingency of 400/220kV Chittorgarh, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Bhinmal ICTs						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Delhi for May 2023

Issue Date: -30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	7100	300	6800	3740	3060		https://www.delhisldc.org/resources/atcttcreport.pdf
Limiting Constraints		N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs.						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of HP for May 2023

Issue Date: - 30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	1400	100	1300	1350	-50		https://hpsldc.com/mrm_category/ttc-atc-report/
Limiting Constraints		N-1 contingency of 400/220kV Nallagarh ICTs. High loading of 220kV Nallagarh-Upernangal D/C						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages

National Load Despatch Centre
Import Capability of Uttarakhand for May 2023

Issue Date: -30th April 2023

Issue Time: 1600

Revision No. 0

Date	Time Period in IST (hrs)	Total Transfer Capability (TTC) (MW)	Reliability Margin (MW)	Available Transfer Capability (ATC) (MW)	Long Term Access (LTA)/ Medium Term Open Access (MTOA) (MW)	Margin Available for Short Term Open Access (STOA) (MW)	Changes in TTC w.r.t. Last Revision	Comments
1st May 2023 to 31st May 2023	00-24	1700	100	1600	1200	400		https://uksldc.in/ttc-atc
Limiting Constraints		N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines						

80% of LTA/MTOA/ISGS allocation capacity considered to account for machine outages