

National Load Despatch Centre
Import Capability of Punjab for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|--|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 10300 | 500 | 9800 | 5497 | 4303 | | https://www.punjab.sldc.org/ATC_TTC.aspx |
| Limiting Constraints | | N-1 contingency of 400/220KV ICT at Rajpura, Ludhiana, Jalandhar, Muktsar Loading close to N-1 contingency limits of 400/220kV Patran, Malerkotla and Patiala ICTs 220 kV underlying network at Jalandhar, Ludhiana and Amritsar | | | | | | |

National Load Despatch Centre
Import Capability of Uttar Pradesh for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|---|--------------------------------|---|---|--|--|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 17300 | 600 | 16700 | 10165 | 6535 | | https://www.upsldc.org/documents/20182/0/ttc_atc_24-11-16/4c79978e-35f2-4aef-8c0f-7f30d878dbde |
| Limiting Constraints | | N-1 contingency of 400/220kV Obra, Allahabad(PG), Gorakhpur (UP), Agra(PG), Lucknow (PG) ICTs | | | | | | |

National Load Despatch Centre
Import Capability of Haryana for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 10300 | 300 | 10000 | 5418 | 4582 | | https://hvpn.org.in/#/atcttc |
| Limiting Constraints | | N-1 contingency of 400/220kV ICT at Deepalpur, Hisar, Kabulpur and Panipat(BBMB) | | | | | | |

National Load Despatch Centre
Import Capability of Rajasthan for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 7600 | 600 | 7000 | 5755 | 1245 | | https://sldc.rajasthan.gov.in/rrvpnl/scheduling/downloads |
| Limiting Constraints | | N-1 contingency of 400/220kV Heerapura, Jodhpur, Bikaner, Ajmer, Merta, Hindaun and Ratangarh ICTs | | | | | | |

National Load Despatch Centre
Import Capability of Delhi for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|--|--------------------------------|---|---|--|--|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 7300 | 300 | 7000 | 4810 | 2190 | | https://www.delhisldc.org/resources/atcttcreport.pdf |
| Limiting Constraints | | N-1 contingency of 400/220kV Mundka, HarshVihar and Bawana (bus-split) ICTs. | | | | | | |

National Load Despatch Centre
Import Capability of Uttarakhand for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|--|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 1710 | 100 | 1610 | 1402 | 208 | | https://uksldc.in/ttc-atc |
| Limiting Constraints | | N-1 contingency of 400/220kV Kashipur ICTs. High loading of 220kV Roorkee-Roorkee and 220kV CBGanj-Pantnagar lines | | | | | | |

National Load Despatch Centre
Import Capability of HP for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|---|-------------------------|--|--------------------------------------|---|-------------------------------------|---|
| 1st November 2024 to 30th November 2024 | 00-24 | 2386 | 100 | 2286 | 1130 | 1156 | | https://hpsldc.com/mrm_category/ttc-atc-report/ |
| Limiting Constraints | | Overloading of 2*100MVA Giri transformers | | | | | | |

National Load Despatch Centre
Import Capability of J&K for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|--------------------------|---|-------------------------|--|--------------------------------------|---|-------------------------------------|----------|
| 1st November 2024 to 30th November 2024 | 00-24 | 3200 | 100 | 3100 | 1977 | 1123 | | |
| Limiting Constraints | | N-1 contingency of 400/220KV ICTs at Amargarh 220 kV underlying network at Amargarh, Wagoora | | | | | | |

National Load Despatch Centre
Import Capability of Chandigarh for November 2024

Issue Date: 30-10-2024

Issue Time: 1600

Revision No. 3

| Date | Time Period in IST (hrs) | Total Transfer Capability (TTC) (MW) | Reliability Margin (MW) | Available Transfer Capability (ATC) (MW) | Approved General Network Access (MW) | Margin Available for Temporary General Network Access(MW) | Changes in TTC w.r.t. Last Revision | Comments |
|---|---------------------------------|---|--------------------------------|---|---|--|--|-----------------|
| 1st November 2024 to 30th November 2024 | 00-24 | 400 | 20 | 380 | 342 | 38 | | |
| Limiting Constraints | | N-1 contingency of 220kV Nallagarh-Kishengarh | | | | | | |